SIEMENS

Product data sheet 3RS1020-1DD20



TEMPERATURE MONITORING RELAY FOR PT100, EXCEEDING OF 2 THRESH. VAL., WIDTH 22ND5 MM 0 C - 200 C, 24V AC/DC 1 NO+1 W, LOAD + CL.-CIRC.CURR. SCREW CONNECTION

General technical details:		
type of voltage		AC/DC
Supply voltage frequency		
• 1 / for auxiliary and control current circuit		
• initial rated value	Hz	50
• final rated value	Hz	60
• 1 / at 50 Hz / for AC / rated value	V	24
• 1 / at 60 Hz / for AC / rated value	V	24
• 1 / for DC / rated value	V	24
Number of measuring circuits		1
Product function		
defect storage		No
reset external		No
Measurable temperature		
• initial value	°C	0
• final value	°C	200
Item designation / according to DIN EN 61346-2		К
Item designation / according to DIN 40719 extendable after IEC 204-2 / according to IEC 750		К
Ambient temperature		
during operating	°C	-25 +60

Mechanical design:			
Design of the electrical connection			
for auxiliary and control current circuit		screw-type terminals	
• jumper socket		Yes	
Design of the sensor / connectable		PT100 (resistance sensor)	
Number of NC contacts / for auxiliary contacts		0	
Number of NO contacts / for auxiliary contacts		1	
Number of change-over switches / for auxiliary contacts		1	
Width	mm	22.5	
Height	mm	102	
Depth	mm	91	

Certificates/approvals:

General Product Approval





Test Certificates other

Special Test

Certificate

Declaration of Conformity

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator:


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3RS1020-1DD20/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RS1020-1DD20





last change: Jan 25, 2013