



RESIDUAL-CURRENT DEVICE COMPON.SUMMATION
 CURR.TRANSF. W/O PICK-UP DELAY WINDOW 120MM
 RTD.FAULT CURRENT 16A

General technical details:

| | | |
|---|----|----------------|
| Item designation / according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 | | K |
| Item designation / according to DIN EN 61346-2 | | K |
| Ambient temperature | | |
| • during operating | °C | -20 ... 70 ... |

Mechanical design:

| | | |
|---|-----------------|-----|
| Diameter / of the feedthrough | mm | 120 |
| Conductor cross section that can be connected / of the terminal | mm ² | 2.5 |
| Width | mm | 200 |
| Height | mm | 85 |
| Depth | mm | 200 |

Certificates/approvals:

General Product Approval

CSA



GOST



UL

Test Certificates[Special Test Certificate](#)**Shipping Approval**

DNV



GL



LRS



RMRS

other[Declaration of Conformity](#)[other](#)**Further information:****Information- and Downloadcenter (Catalogs, Brochures,...)**<http://www.siemens.com/industrial-controls/catalogs>**Industry Mall (Online ordering system)**<http://www.siemens.com/industrial-controls/mall>**CAX-Online-Generator**<http://www.siemens.com/cax>**Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**<http://support.automation.siemens.com/WW/view/en/3UL2203-3B/all>**Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)**http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3UL2203-3B

last change:

Jan 21, 2013